

Facility Name _____

Pool or Spa _____

Monthly period _____ to _____, 20____

	Test when opening & closing + every 4 hours											Daily				Weekly			Comments				
	Free Cl/Br-	Comb. Cl	pH	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	Flowrate AM	Flowrate PM	Clarity**	Temp		Alkalinity	Ca Hardness	CYA	Sat Index
Time																							
Date																							
1																							
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							
11																							
12																							
13																							
14																							
15																							
16																							
17																							
18																							
19																							
20																							
21																							
22																							
23																							
24																							
25																							
26																							
27																							
28																							
29																							
30																							
31																							

**Clarity Good, Marginal, Poor: Good means very clear; marginal means cloudy but main drain still visible, poor means drain obscured

Parameters Cl 2-8 ppm; Comb Cl ≤ 0.5ppm; Br 2-10 ppm; pH 7.2-7.8; Alk 60-220 (varies by pool); Sat index -0.5 to + 0.5; CYA <100ppm; ORP >650