

Facility Name _____ Pool or Spa _____

Monthly period _____ to _____, 2_____		Test when opening & closing + every 4 hours											Daily				Weekly			Comments					
Time	Date	Free Cl/Br-	Comb. Cl	pH	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	* ORP *	Free Cl/Br-	Comb. Cl	pH	Flowrate AM	Flowrate PM	Clarity**	Temp		Alkalinity	Ca Hardness	CYA	Sat Index	
1																									
2																									
3																									
4																									
5																									
6																									
7																									
8																									
9																									
10																									
11																									
12																									
13																									
14																									
15																									
16																									
17																									
18																									
19																									
20																									
21																									
22																									
23																									
24																									
25																									
26																									
27																									
28																									
29																									
30																									
31																									

**Clarity Good, Marginal, Poor: Good means very clear; marginal means cloudy but main drain still visible, poor means drain obscured

Parameters Cl 2-8 ppm; Comb Cl ≤ 0.5ppm; Br 2-10 ppm; pH 7.2-7.8; Alk 60-220 (varies by pool); Sat index -0.5 to + 0.5; CYA <100ppm; ORP >650