

CIRCLE ONE: POOL / SPA

WATER CHEMISTRY LOG

DATE	TIME	DAILY							WEEKLY Total Alkalinity	MONTHLY			COMMENTS <i>(i.e. Self Closed, Corrective Actions Taken)</i>
		Water Clarity	Chlorine/Bromine			pH	Temp	Flow Rate		Calcium Hardness	Cyanuric Acid	Saturation Index	
			Total	Free	Combined								

**IMMEDIATE POOL CLOSURE FOR BOLDED ITEMS**

<p><b><u>Pool</u></b>  <b>Free Chlorine (S:2-10ppm, U:1-10ppm)</b>  <b>Total Bromine (3-8ppm)</b>                  Combined Chlorine (<math>\leq 0.4</math>ppm)                  Cyanuric Acid (<math>\leq 50</math>ppm)</p>	<p><b><u>Spa</u></b>  <b>Free Chlorine (3-10ppm)</b>  <b>Total Bromine (4-8ppm)</b>                  Combined Chlorine (<math>\leq 0.4</math>ppm)</p>	<p><b><u>General</u></b>                  pH (7.2-7.8) (<b>&lt;6.5 OR &gt;8</b>)  <b>Temperature (<math>\leq 104</math>)</b>                  Total Alkalinity (60-180ppm)                  Calcium Hardness (1,000ppm)</p>	<p><b>ORP (<math>\geq 650</math>)</b>                  Water Clarity (<math>\geq</math> moderate) (<b>poor</b>)                  Start corrective action when clarity is mod                  excellent &gt; good &gt; moderate &gt; poor</p>
--	---	---	---